



CERTIFICATE

The company

TECE GmbH

Hollefeldstraße 57 48282 Emsdetten GERMANY

hereby receives the confirmation that the product/s

Plastic piping systems for warm water floor heating systems and radiator connecting

of the type

TECE floor / SLQ

conforms to

DIN 4726:2008-10 DIN EN ISO 15875-2:2004-03 DIN EN ISO 15875-3:2004-03

DIN EN ISO 15875-5:2004-03

Certification scheme plastic piping systems for warm water floor heating systems and radiator connecting (Edition: 2011-06)

and is granted the licence to use the mark



in conjunction with the Registration No. below.

Registration No.: 3V355 PE-Xc

This Certificate is valid until 2017-01-31.

See annex for further information.

DIN CERTCO Gesellschaft für Konformitätsbewertung mbH Alboinstraße 56, 12103 Berlin



2012-03-07

Dipl.-Ing. Peter Suxdorf - Managing Director -

Annex

to the Certificate with Registration No. 3V355 PE-Xc, dated 2012-03-07

Technical data

Pipe:

- Production plant: Strzelin, Polen
- Material designation: PE-RT
- Nominal-outside diameter x nominal thickness: 14 x 2 mm, 16 x 2 mm, 17 x 2 mm, 18 x 2 mm, 20 x 2 mm
- Design class: C
- Application class and operating pressure: Class 4 and 5 / 6 bar

Fitting/Connector:

- Name of the manufacturer: Simplex Armaturen & Systeme GmbH
- Production plant: Argenbühl Eisenharz
- Type of the fitting: screw connector
- Material designation: metal
- Type designation: Mechanical fitting made of metal for plastic pipes (M-MK)
- Article number:

Fitting/Connector:

- Name of the manufacturer: TECE GmbH
- Production plant: Emsdetten
- Type of fitting: sliding collar connector
- Material designation: metal
- Type designation: Mechanical fitting made of metal for plastic pipes (M-MK)
- Article number:

Testing laboratory / Inspection body

Staatliche Materialprüfungsanstalt Darmstadt Abt. Kunststoffe Grafenstraße 2 64283 Darmstadt

Test report(s)

K 11 1533.1 dated 2012-01-31 K 11 1533.2 dated 2012-01-31

