

Determination of the filtration performance of air filter CA-Q according to EN ISO 16890:2016



Requested by **Filtech BV**
Luc Taeymans
Brabantse Hoek 10
5071 NM Udenhout, Netherlands
luc.taeymans@filtech.eu

Order ref. Q3JAPT200065-01, dated 23.7.2020

Contact person **Eurofins Expert Services Oy**
Antti Korhonen
Kemistintie 3, 02150
Espoo, Finland
AnttiKorhonen@eurofins.fi

Assignment	Determination of the filtration performance of air filter CA-Q according to EN ISO 16890:2016
Sample details	The customer delivered two air filters which is detailed in Appendix 1. One was randomly selected for the test. The sample were received 24.7.2020. The measurements were made 17. - 19.8.2020.
Methods	Deviating from the standard the test air flow rate is lower than 0.25 m³/s. The tests were made according to EN ISO 16890:2016 standard series /1, 2, 3 and 4/ The filter discharging treatment were made by exposing the filter to isopropanol (IPA) vapor. The purity of the isopropanol used in the test was >99.5 %. The air flow rates were measured with a calibrated orifice plate with corner pressure tappings. The instruments used in the measurements are presented in Appendix 8. FINAS Finnish Accreditation Service has accredited our laboratory (T001, Appendix 1.08, Eurofins Expert Services Oy) to perform measurements according to EN ISO 16890:2016 standard series.
Results	A summary of the test results, fractional efficiency values and calculation of the particulate matter efficiencies (ePM) are presented in Appendix 1. Initial and conditioned fractional efficiency measurement results are presented in accordance with EN ISO 16890-2:2016 and EN ISO 16890-4:2016 in Appendix 2. Airflow rate and pressure drop measurement results are presented in accordance with EN ISO 16890-3:2016 in Appendix 3. Test aerosol particle numbers measured in determination of initial fractional efficiency is presented in Appendix 4 and for conditioned fractional efficiency in Appendix 5. The net effective filtering area 0.6 m ² was calculated using the following measured approximate dimensions: pleat depth 18 mm, pleat tip width 1 mm pleat width 155 mm, number of pleats per filter pack 94, number of packs in the filter 1. Normalized downstream particle size distribution and measured efficiencies are presented in Appendix 6. The EN ISO 16890-1:2016 guideline for interpretation of test reports is presented in Appendix 7. The measurements have been made so that the accuracy demands set in the standard ISO 16890-2 are fulfilled, i.e. pressure difference accuracy $\pm 2\%$ in the range 0 - 70 Pa, above 70 Pa 3 % of the measured value, uncertainty of air flow rate $\leq 5\%$ at a 95 % confidence level. The results are only valid for the tested filter sample.

References

- /1/ EN ISO 16890-1:2016. Air filters for general ventilation - Part 1: Technical specifications, requirements and classification system based upon particulate matter efficiency (ePM)
- /2/ EN ISO 16890-2:2016. Air filters for general ventilation - Part 2: Measurement of fractional efficiency and air flow resistance
- /3/ EN ISO 16890-3:2016. Air filters for general ventilation - Part 3: Determination of the gravimetric efficiency and the air flow resistance versus the mass of test dust captured
- /4/ EN ISO 16890-4:2016. Air filters for general ventilation - Part 4: Conditioning method to determine the minimum fractional test efficiency

Espoo, 20.8.2020

*Antti Korhonen
Consulting Expert*

Appendices	8
Distribution	Customer, electronically approved

EN ISO 16890-1:2016 Air Filter Test Results
GENERAL

Test no.:	204224	Device receiving date:	24.7.2020
Test requested by:	Filtech BV	Date of test:	17. - 19.8.2020
Device delivered by:	Filtech BV	Operator:	JR

DEVICE TESTED

Model	CA-Q	Manufacturer	Construction
		Filtech BV	Panel
Type of medium	Net effective filtering area	Filter dimensions (width x height x depth)	
Synthetic fibre	0.6 m ²	160 mm x 500 mm x 22 mm	

TEST DATA



Test air flow rate 0.097 m ³ /s	Test air temperature 23 - 23 °C	Test air relative humidity 47 - 53 %	Test aerosol DEHS and KCl	Loading dust -
---	------------------------------------	---	------------------------------	-------------------

CONDITIONING ENVIRONMENT

Time of conditioning 24 h	Room temperature 19 - 20 °C	Room relative humidity 42 - 45 %	Barometric pressure 101.1 - 101.5 kPa	Evaporated IPA amount Not measured
------------------------------	--------------------------------	-------------------------------------	--	---------------------------------------

RESULTS

Initial pressure drop 53 Pa	Initial gravimetric arrestance -	ePM ₁ , min 59 %	ePM _{2.5} , min 70 %	ePM ₁₀ , min 90 %	ISO rating
Final test pressure drop -	Test dust capacity -	ePM ₁ 60 %	ePM _{2.5} 71 %	ePM ₁₀ 90 %	ISO ePM ₁ 60 %
Remarks: -					



NOTE: The results of this test relate only to the test device in the condition stated herein. The performance results cannot be themselves be quantitatively applied to predict filtration performance in all "real life" environments.



The results are only valid for the tested sample(s).
This report may be published in its entity, parts of it only with a written permission by Eurofins

**Fractional efficiency values
EN ISO 16890-1,2,4:2016**

Air filter: CA-Q

Test no.: 204224

Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)

Air flow rate: 0.097 m³/s

OPC Bin, i	Particle size			Fractional efficiency		
	Δd_i µm	\bar{d}_i µm	$\Delta \ln d_i$ µm	E_i %	$E_{D,i}$ %	$E_{A,i}$ %
1	0.30 - 0.40	0.35	0.28768	49	46	48
2	0.40 - 0.55	0.47	0.31845	59	57	58
3	0.55 - 0.70	0.62	0.24116	68	66	67
4	0.70 - 1.00	0.84	0.35667	77	76	77
5	1.00 - 1.30	1.14	0.26236	88	86	87
6	1.30 - 1.60	1.44	0.20764	92	90	91
7	1.60 - 2.20	1.88	0.31845	95	95	95
8	2.20 - 3.00	2.57	0.31015	98	98	98
9	3.00 - 4.00	3.46	0.28768	99	100	99
10	4.00 - 5.50	4.69	0.31845	100	100	100
11	5.50 - 7.00	6.20	0.24116	100	100	100
12	7.00 - 10.0	8.37	0.35667	100	100	100

Symbols and units Δd_i Particle size range i , µm \bar{d}_i Geometric mean diameter of a size range i , µm $\Delta \ln d_i$ Logarithmic width of particle diameter size range i E_i Initial fractional efficiency of particle size range i of the untreated and unloaded filter element, % $E_{D,i}$ Fractional efficiency of particle size range i of the filter element after an artificial conditioning step, % $E_{A,i}$ Average fractional efficiency of particle size range i , %

**Calculation of the particulate matter efficiencies (ePM)
EN ISO 16890-1:2016**

Air filter: CA-Q

Test no.: 204224

Test aerosols: DEHS (0.3 - 1 μm) and KCl (1 - 10 μm)

Air flow rate: 0.097 m^3/s

OPC Bin, i	Particle size			$q_{3u}(\bar{d}_i)$	$q_{3u}(\bar{d}_i) * \Delta \ln d_i$	Urban size distribution			$ePM_{x, \min} \%$	$ePM_x \%$
	Δd_i μm	\bar{d}_i μm	$\Delta \ln d_i$ μm			$E_{D,i} * q_{3u}(\bar{d}_i)$ $* \Delta \ln d_i$	$E_{A,i} * q_{3u}(\bar{d}_i)$ $* \Delta \ln d_i$			
1	0.30 - 0.40	0.35	0.28768	0.226274	0.065095	0.030267	0.031082			
2	0.40 - 0.55	0.47	0.31845	0.198908	0.063343	0.036415	0.037027			
3	0.55 - 0.70	0.62	0.241116	0.158372	0.038193	0.025319	0.025679			
4	0.70 - 1.00	0.84	0.35667	0.115223	0.041097	0.031349	0.031540	$ePM_{1, \min}$	ePM_1	
Σ line 1-4				0.207728	0.123350	0.125329	59	60		
5	1.00 - 1.30	1.14	0.26236	0.085032	0.022309	0.019098	0.019350			
6	1.30 - 1.60	1.44	0.20764	0.076177	0.015817	0.014291	0.014397			
7	1.60 - 2.20	1.88	0.31845	0.080218	0.025546	0.024299	0.024299			
8	2.20 - 3.00	2.57	0.31015	0.099839	0.030966	0.030409	0.030394	$ePM_{2.5, \min}$	$ePM_{2.5}$	
Σ line 1-8				0.302366	0.211447	0.213768	70	71		

OPC Bin, i	Particle size			$q_{3r}(\bar{d}_i)$	$q_{3r}(\bar{d}_i) * \Delta \ln d_i$	Rural size distribution			$ePM_x \%$	
	Δd_i μm	\bar{d}_i μm	$\Delta \ln d_i$ μm			$E_{D,i} * q_{3r}(\bar{d}_i)$ $* \Delta \ln d_i$	$E_{A,i} * q_{3r}(\bar{d}_i)$ $* \Delta \ln d_i$			
1	0.30 - 0.40	0.35	0.28768	0.094121	0.027077			0.012929		
2	0.40 - 0.55	0.47	0.31845	0.083946	0.026733			0.015627		
3	0.55 - 0.70	0.62	0.241116	0.074324	0.017924			0.012051		
4	0.70 - 1.00	0.84	0.35667	0.070137	0.025016			0.019199		
5	1.00 - 1.30	1.14	0.26236	0.076281	0.020013			0.017359		
6	1.30 - 1.60	1.44	0.20764	0.088326	0.018340			0.016693		
7	1.60 - 2.20	1.88	0.31845	0.108042	0.034406			0.032727		
8	2.20 - 3.00	2.57	0.31015	0.137262	0.042573			0.041786		
9	3.00 - 4.00	3.46	0.28768	0.167084	0.048067			0.047817		
10	4.00 - 5.50	4.69	0.31845	0.195424	0.062233			0.062162		
11	5.50 - 7.00	6.20	0.241116	0.216707	0.052261			0.052234		
12	7.00 - 10.0	8.37	0.35667	0.231428	0.082545			0.082505		
Σ line 1-12				0.457189				0.413089	90	

Symbols and units

- Δd_i Particle size range i , μm
- \bar{d}_i Geometric mean diameter of a size range i , μm
- $\Delta \ln d_i$ Logarithmic width of particle diameter size range i
- $q_{3u}(\bar{d})$ Discrete urban particle volume distribution, dimensionless
- $q_{3r}(\bar{d})$ Discrete rural particle volume distribution, dimensionless
- $E_{D,i}$ Fractional efficiency of particle size range i of the filter element after an artificial conditioning step, %
- $E_{A,i}$ Average fractional efficiency of particle size range i , %
- $ePM_{x, \min}$ Minimum particulate matter efficiency value of the conditioned filter, %
- ePM_x Particulate matter efficiency, %



The results are only valid for the tested sample(s).
This report may be published in its entity, parts of it only with a written permission by Eurofins


**Initial and conditioned fractional efficiency
EN ISO 16890-2,4:2016**

Air filter: CA-Q

Test no.: 204224

Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)

Air flow rate: 0.097 m³/s



Particle size Δd_i µm	d_i µm	Fractional efficiency and upstream concentration					
		Initial, q _v = 100 % %	#/dm ³	Conditioned, q _v = 100 % %	#/dm ³	Conditioned, q _v = 50 % %	#/dm ³
0.30 - 0.40	0.35	49.0	27 340	46.5	28 157	45.1	18 306
0.40 - 0.55	0.47	59.4	23 594	57.5	24 188	56.0	15 865
0.55 - 0.70	0.62	68.2	14 237	66.3	14 665	65.3	9 902
0.70 - 1.00	0.84	77.2	15 753	76.3	16 265	75.4	11 620
1.00 - 1.30	1.14	87.9	3 820	85.6	3 983		
1.30 - 1.60	1.44	91.7	3 641	90.4	3 956		
1.60 - 2.20	1.88	95.1	5 637	95.1	6 045		
2.20 - 3.00	2.57	98.1	4 215	98.2	4 415		
3.00 - 4.00	3.46	99.5	3 337	99.5	3 448		
4.00 - 5.50	4.69	99.9	2 058	99.9	2 128		
5.50 - 7.00	6.20	99.9	643	100.0	654		
7.00 - 10.0	8.37	99.9	835	100.0	781		
DEHS concentration		103 819		106 027			
KCl concentration		84 941		87 028			
Pressure drop		53 Pa		55 Pa			
Device mass		97 g		99 g			

 Particle counter coincidence value is 250 000 #/dm³
Symbols and units
 Δd_i Particle size range, µm

 \bar{d}_i Geometric mean diameter of a size range i, µm

 q_v Air flow rate at filter


The results are only valid for the tested sample(s).
This report may be published in its entity, parts of it only with a written permission by Eurofins

Air flow rate and pressure drop
EN ISO 16890-2:2016

Air filter: CA-Q
Test no.: 204224
Air flow rate: 0.097 m³/s

Date	Loaded dust m _{tot} g	Calibrated orifice plate ¹⁾				t °C	φ %	p _a kPa	ρ kg/m ³	q _v m ³ /s	Filter Δp Pa	Δp _{1.20} Pa	% of rated air flow	
		t _f °C	p _{sf} kPa	Δp _f Pa	q _m kg/m ³									
Clean Filter														
17.8.2020	-	23.2	-0.099	627	0.144	23.4	46.7	101.7	1.189	0.121	70	69	125 %	
"	-	23.2	-0.083	401	0.115	23.4	46.6	101.7	1.189	0.096	54	53	100 %	
"	-	23.3	-0.070	233	0.087	23.4	46.7	101.7	1.189	0.073	40	40	75 %	
"	-	23.3	-0.055	100	0.056	23.4	46.9	101.7	1.189	0.047	26	26	50 %	
"	-	23.3	-0.040	24	0.028	23.4	47.3	101.7	1.188	0.023	13	13	25 %	
Clean filter pressure drop is proportional to (q _v) ⁿ , where n = 1.011														
Conditioned filter														
19.8.2020	-	22.8	-0.084	407	0.115	23.1	52.5	101.5	1.186	0.097	56	55	100 %	
"	-	22.9	-0.055	102	0.057	23.1	50.0	101.5	1.187	0.048	26	26	50 %	

Symbols and units

m _{tot}	Cumulative mass of dust fed to filter, g	t _f	Temperature at air flow meter, °C
p _a	Absolute air pressure upstream of filter, kPa	ρ	Air density upstream of filter, kg/m ³
p _{sf}	Air flow meter static pressure, kPa	φ	Relative humidity upstream of filter, %
q _m	Mass flow rate, kg/s	Δp	Measured filter pressure drop, Pa
q _v	Air flow rate at filter, m ³ /s	Δp _f	Air flow meter differential pressure, Pa
t	Temperature upstream of filter, °C	Δp _{1.20}	Filter pressure drop at air density 1.20 kg/m ³ , Pa

¹⁾ Orifice plate dimensions

Duct dimensions: 610 mm x 610 mm
Orifice diameter: 216 mm

Correlation data for initial efficiency
EN ISO 16890-2:2016

Air filter: CA-Q

Test no.: 204224

Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)

Air flow rate: 0.097 m³/s

OPC Bin, i	\bar{d}_i µm	Initial and final background					
		$U_{B,c,b}$	$U_{B,c,f}$	$U_{B,c}$	$D_{B,c,b}$	$D_{B,c,f}$	$D_{B,c}$
1	0.35	0	0	0	0	0	0
2	0.47	0	0	0	0	0	0
3	0.62	0	0	0	0	0	0
4	0.84	0	0	0	0	0	0
5	1.14	0	0	0	0	0	0
6	1.44	0	0	0	0	0	0
7	1.88	0	0	0	0	0	0
8	2.57	0	0	0	0	0	0
9	3.46	0	0	0	0	0	0
10	4.69	0	0	0	0	0	0
11	6.20	0	0	0	0	0	0
12	8.37	0	0	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Upstream correlation (five measurements)					Downstream correlation (five measurements)						
		1	2	3	4	5	$U_{c,tot}$	1	2	3	5	$D_{c,tot}$	
1	0.35	24132	25877	26586	27533	27163	131291	22335	24284	25582	25670	25778	123649
2	0.47	20754	22071	22941	23618	23292	112676	19652	20893	22039	22377	22467	107428
3	0.62	12418	13566	14017	14219	14096	68316	12209	13316	14005	14165	14147	67842
4	0.84	13650	14962	15353	15754	15726	75445	12672	13821	14385	14884	14821	70583
5	1.14	3681	3752	3846	3941	3742	18962	4094	4175	4276	4415	4315	21275
6	1.44	3475	3581	3728	3710	3648	18142	3435	3465	3568	3573	3540	17581
7	1.88	5466	5550	5618	5451	5519	27604	5039	4989	4994	5329	5182	25533
8	2.57	4083	3887	4042	4107	4033	20152	3829	3717	3687	3875	3745	18853
9	3.46	3216	3223	3376	3417	3226	16458	3083	3113	3140	3140	3046	15522
10	4.69	2006	1981	2096	2010	1943	10036	1907	1926	2014	1972	1903	9722
11	6.20	575	671	642	641	645	3174	586	589	634	659	559	3027
12	8.37	746	751	826	814	803	3940	636	703	658	684	669	3350

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Correlation ratios (five measurements)						Uncertainty limits			
		R_1	R_2	R_3	R_4	R_5	R_{avg}	Pass/Fail	δ_c	e_c	Pass/Fail
1	0.35	0.926	0.938	0.962	0.932	0.949	0.942	Pass	0.0144	0.0179	Pass
2	0.47	0.947	0.947	0.961	0.947	0.965	0.953	Pass	0.0087	0.0108	Pass
3	0.62	0.983	0.982	0.999	0.996	1.004	0.993	Pass	0.0098	0.0122	Pass
4	0.84	0.928	0.924	0.937	0.945	0.942	0.935	Pass	0.0090	0.0112	Pass
5	1.14	1.112	1.113	1.112	1.120	1.153	1.122	Pass	0.0177	0.0220	Pass
6	1.44	0.988	0.968	0.957	0.963	0.970	0.969	Pass	0.0118	0.0147	Pass
7	1.88	0.922	0.899	0.889	0.978	0.939	0.925	Pass	0.0352	0.0437	Pass
8	2.57	0.938	0.956	0.912	0.944	0.929	0.936	Pass	0.0165	0.0205	Pass
9	3.46	0.959	0.966	0.930	0.919	0.944	0.944	Pass	0.0195	0.0241	Pass
10	4.69	0.951	0.972	0.961	0.981	0.979	0.969	Pass	0.0129	0.0160	Pass
11	6.20	1.019	0.878	0.988	1.028	0.867	0.956	Pass	0.0779	0.0967	Pass
12	8.37	0.853	0.936	0.797	0.840	0.833	0.852	Pass	0.0516	0.0640	Pass

Symbols and units

\bar{d}_i	Geometric mean diameter of a size range i, µm	$D_{B,c}$	Downstream background count average for correlation
$U_{B,c,b}$	Upstream begining background count for correlation	$U_{c,tot}$	Total upstream particle counts
$U_{B,c,f}$	Upstream final background count	$D_{c,tot}$	Total downstream particle counts
$U_{B,c}$	Upstream background count average for correlation	R_{avg}	Average correlation ratio
$D_{B,c,b}$	Downstream begining background count for correlation	δ_c	Standard deviation of the correlation values
$D_{B,c,f}$	Downstream final background count	e_c	Uncertainty at 95 % confidence interval for correlation values



The results are only valid for the tested sample(s).
This report may be published in its entity, parts of it only with a written permission by Eurofins

Initial efficiency data
EN ISO 16890-2:2016

Air filter: CA-Q

Test no.: 204224

Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)

Air flow rate: 0.097 m³/s

OPC Bin, i	\bar{d}_i µm	Initial and final background					
		$U_{B,e,b}$	$U_{B,e,f}$	$U_{B,e}$	$D_{B,e,b}$	$D_{B,e,f}$	$D_{B,e}$
1	0.35	0	0	0	0	0	0
2	0.47	0	0	0	0	0	0
3	0.62	0	0	0	0	0	0
4	0.84	0	0	0	0	0	0
5	1.14	0	0	0	0	0	0
6	1.44	0	0	0	0	0	0
7	1.88	0	0	0	0	0	0
8	2.57	0	0	0	0	0	0
9	3.46	0	0	0	0	0	0
10	4.69	0	0	0	0	0	0
11	6.20	0	0	0	0	0	0
12	8.37	0	0	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Upstream efficiency (five measurements)					Downstream efficiency (five measurements)						
		1	2	3	4	5	$U_{e,tot}$	1	2	3	5		
1	0.35	27468	27165	27444	27264	27361	136702	12606	12942	13153	13520	13413	65634
2	0.47	23317	23709	23655	23668	23622	117971	8743	8910	9183	9433	9369	45638
3	0.62	14034	14277	14451	14198	14227	71187	4390	4313	4418	4702	4662	22485
4	0.84	15832	15870	15580	15824	15660	78766	3330	3209	3345	3454	3447	16785
5	1.14	3402	3789	3923	4055	3931	19100	435	544	554	537	534	2604
6	1.44	3225	3719	3762	3794	3706	18206	247	303	310	299	310	1469
7	1.88	5111	5710	5806	5798	5758	28183	230	238	261	283	261	1273
8	2.57	3687	4255	4314	4442	4379	21077	62	90	92	61	69	374
9	3.46	3003	3329	3470	3451	3432	16685	11	16	14	22	24	87
10	4.69	1790	2099	2055	2156	2191	10291	2	4	2	1	4	13
11	6.20	593	635	692	629	665	3214	2	0	0	1	0	3
12	8.37	674	885	859	860	899	4177	2	0	0	1	0	3

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Observed penetration (five measurements)					
		$P_{o,1}$	$P_{o,2}$	$P_{o,3}$	$P_{o,4}$	$P_{o,5}$	P_o
1	0.35	0.459	0.476	0.479	0.496	0.490	0.480
2	0.47	0.375	0.376	0.388	0.399	0.397	0.387
3	0.62	0.313	0.302	0.306	0.331	0.328	0.316
4	0.84	0.210	0.202	0.215	0.218	0.220	0.213
5	1.14	0.128	0.144	0.141	0.132	0.136	0.136
6	1.44	0.077	0.081	0.082	0.079	0.084	0.081
7	1.88	0.045	0.042	0.045	0.049	0.045	0.045
8	2.57	0.017	0.021	0.021	0.014	0.016	0.018
9	3.46	0.004	0.005	0.004	0.006	0.007	0.005
10	4.69	0.001	0.002	0.001	0.000	0.002	0.001
11	6.20	0.003	0.000	0.000	0.002	0.000	0.001
12	8.37	0.003	0.000	0.000	0.001	0.000	0.001

OPC Bin, i	\bar{d}_i µm	Penetration data reduction			Uncertainty limits		Efficiency %
		P	δ	e	Static	Dynamic	
1	0.35	0.510	0.017	0.021	0.05	0.036	Pass 49.0
2	0.47	0.406	0.012	0.015	0.05	0.028	Pass 59.4
3	0.62	0.318	0.013	0.017	0.05	0.022	Pass 68.2
4	0.84	0.228	0.008	0.010	0.05	0.016	Pass 77.2
5	1.14	0.121	0.006	0.007	0.05	0.008	Pass 87.9
6	1.44	0.083	0.003	0.004	0.05	0.006	Pass 91.7
7	1.88	0.049	0.003	0.004	0.05	0.003	Pass 95.1
8	2.57	0.019	0.004	0.004	0.05	0.001	Pass 98.1
9	3.46	0.005	0.002	0.002	0.05	0.001	Pass 99.5
10	4.69	0.001	0.001	0.001	0.05	0.000	Pass 99.9
11	6.20	0.001	0.002	0.002	0.05	0.000	Pass 99.9
12	8.37	0.001	0.002	0.002	0.05	0.000	Pass 99.9

Symbols and units

\bar{d}_i	Geometric mean diameter of a size range i, µm	$U_{e,tot}$	Total upstream particle counts
$U_{B,e,b}$	Upstream begining background count for penetration	$D_{e,tot}$	Total downstream particle counts
$U_{B,e,f}$	Upstream final background count	P_o	Observed penetration, -
$U_{B,e}$	Upstream background count average for penetration	P	Penetration, -
$D_{B,e,b}$	Downstream begining background count for penetration	δ_o	Standard deviation of the observed penetration
$D_{B,e,f}$	Downstream final background count	δ	Standard deviation of the penetration
$D_{B,e}$	Downstream background count average for penetration	e	Uncertainty at 95 % confidence interval for penetration values



FINAS
 Finnish Accreditation Service
 T001 (EN ISO/IEC 17025)

The results are only valid for the tested sample(s).
 This report may be published in its entity, parts of it only with a written permission by Eurofins

Correlation data for conditioned efficiency
EN ISO 16890-2:2016

Air filter: CA-Q

Test no.: 204224

Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)

Air flow rate: 0.097 m³/s

OPC Bin, i	\bar{d}_i µm	Initial and final background					
		$U_{B,c,b}$	$U_{B,c,f}$	$U_{B,c}$	$D_{B,c,b}$	$D_{B,c,f}$	$D_{B,c}$
1	0.35	0	0	0	0	0	0
2	0.47	0	0	0	0	0	0
3	0.62	0	0	0	0	0	0
4	0.84	0	0	0	0	0	0
5	1.14	0	0	0	0	0	0
6	1.44	0	0	0	0	0	0
7	1.88	0	0	0	0	0	0
8	2.57	0	0	0	0	0	0
9	3.46	0	0	0	0	0	0
10	4.69	0	0	0	0	0	0
11	6.20	0	0	0	0	0	0
12	8.37	0	0	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Upstream correlation (five measurements)					Downstream correlation (five measurements)					
		1	2	3	4	5	$U_{c,tot}$	1	2	3	5	$D_{c,tot}$
1	0.35	27584	28128	28157	28550	28468	140887	26864	27184	26654	27015	26790 134507
2	0.47	23933	24000	24238	24086	24242	120499	23081	23485	23610	23445	23344 116965
3	0.62	14618	14629	14876	14852	14989	73964	14726	14975	14919	14766	14620 74006
4	0.84	15935	16373	16283	16489	16486	81566	15177	15008	14911	15017	15180 75293
5	1.14	3664	3755	3954	4051	4035	19459	4006	4001	4263	4129	4220 20619
6	1.44	3612	3647	3877	3869	4169	19174	3209	3344	3592	3560	3552 17257
7	1.88	5333	5533	5824	5777	6025	28492	4977	5148	5268	5460	5643 26496
8	2.57	4027	4211	4203	4342	4406	21189	3710	3738	3970	3931	4052 19401
9	3.46	3275	3274	3504	3456	3449	16958	3102	2991	3269	3230	3275 15867
10	4.69	2052	2045	2096	2048	2154	10395	1963	1906	1989	1948	2072 9878
11	6.20	550	616	685	641	719	3211	626	604	636	681	3151
12	8.37	775	790	856	854	952	4227	674	739	666	736	793 3608

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Correlation ratios (five measurements)						Uncertainty limits			
		R_1	R_2	R_3	R_4	R_5	R_{avg}	Pass/Fail	δ_c	e_c	Pass/Fail
1	0.35	0.974	0.966	0.947	0.946	0.941	0.955	Pass	0.0144	0.0179	Pass
2	0.47	0.964	0.979	0.974	0.973	0.963	0.971	Pass	0.0067	0.0083	Pass
3	0.62	1.007	1.024	1.003	0.994	0.975	1.001	Pass	0.0177	0.0220	Pass
4	0.84	0.952	0.917	0.916	0.911	0.921	0.923	Pass	0.0167	0.0207	Pass
5	1.14	1.093	1.066	1.078	1.019	1.046	1.060	Pass	0.0289	0.0358	Pass
6	1.44	0.888	0.917	0.926	0.920	0.852	0.901	Pass	0.0309	0.0384	Pass
7	1.88	0.933	0.930	0.905	0.945	0.937	0.930	Pass	0.0153	0.0189	Pass
8	2.57	0.921	0.888	0.945	0.905	0.920	0.916	Pass	0.0211	0.0261	Pass
9	3.46	0.947	0.914	0.933	0.935	0.950	0.936	Pass	0.0143	0.0178	Pass
10	4.69	0.957	0.932	0.949	0.951	0.962	0.950	Pass	0.0113	0.0140	Pass
11	6.20	1.138	0.981	0.882	0.992	0.947	0.988	Pass	0.0043	0.1171	Pass
12	8.37	0.870	0.935	0.778	0.862	0.833	0.856	Pass	0.0573	0.0712	Pass

Symbols and units

\bar{d}_i	Geometric mean diameter of a size range i, µm	$D_{B,c}$	Downstream background count average for correlation
$U_{B,c,b}$	Upstream begining background count for correlation	$U_{c,tot}$	Total upstream particle counts
$U_{B,c,f}$	Upstream final background count	$D_{c,tot}$	Total of the downstream particle counts
$U_{B,c}$	Upstream background count average for correlation	R_{avg}	Average correlation ratio
$D_{B,c,b}$	Downstream begining background count for correlation	δ_c	Standard deviation of the correlation values
$D_{B,c,f}$	Downstream final background count	e_c	Uncertainty at 95 % confidence interval for correlation values


FINAS
Finnish Accreditation Service
T001 (EN ISO/IEC 17025)

The results are only valid for the tested sample(s).
This report may be published in its entity, parts of it only with a written permission by Eurofins

Conditioned efficiency data
EN ISO 16890-2:2016

Air filter: CA-Q
Test no.: 204244
Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)
Air flow rate: 0.097 m³/s

OPC Bin, i	\bar{d}_i µm	Initial and final background					
		$U_{B,e,b}$	$U_{B,e,f}$	$U_{B,e}$	$D_{B,e,b}$	$D_{B,e,f}$	$D_{B,e}$
1	0.35	0	0	0	0	0	0
2	0.47	0	0	0	0	0	0
3	0.62	0	0	0	0	0	0
4	0.84	0	0	0	0	0	0
5	1.14	0	0	0	0	0	0
6	1.44	0	0	0	0	0	0
7	1.88	0	0	0	0	0	0
8	2.57	0	0	0	0	0	0
9	3.46	0	0	0	0	0	0
10	4.69	0	0	0	0	0	0
11	6.20	0	0	0	0	0	0
12	8.37	0	0	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Upstream efficiency (five measurements)					Downstream efficiency (five measurements)				
		1	2	3	4	5	$U_{e,tot}$	1	2	3	5
1	0.35	25994	27675	28775	29229	29113	140786	12578	14254	14764	15223
2	0.47	22486	23845	24682	24813	25116	120942	8806	9859	10306	10441
3	0.62	13478	14444	15090	15147	15165	73324	4421	4798	5084	5299
4	0.84	14942	16162	16510	16795	16917	81326	3162	3558	3657	3744
5	1.14	4276	4203	3927	3773	3736	19915	665	586	641	573
6	1.44	4500	4192	3792	3652	3644	19780	391	366	353	306
7	1.88	6583	6362	5900	5698	5683	30226	350	268	239	250
8	2.57	4801	4625	4375	4181	4092	22074	75	79	71	64
9	3.46	3627	3591	3477	3281	3264	17240	12	21	15	13
10	4.69	2107	2181	2217	2070	2066	10641	5	3	1	0
11	6.20	602	667	691	659	649	3268	0	0	0	0
12	8.37	725	791	771	834	783	3904	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Observed penetration (five measurements)					
		P_{o1}	P_{o2}	P_{o3}	P_{o4}	P_{o5}	P_o
1	0.35	0.484	0.515	0.513	0.521	0.522	0.511
2	0.47	0.392	0.413	0.418	0.421	0.420	0.413
3	0.62	0.328	0.332	0.337	0.350	0.340	0.337
4	0.84	0.212	0.220	0.222	0.220	0.221	0.219
5	1.14	0.156	0.139	0.163	0.152	0.153	0.153
6	1.44	0.087	0.087	0.093	0.084	0.083	0.087
7	1.88	0.053	0.042	0.041	0.047	0.044	0.045
8	2.57	0.016	0.017	0.016	0.018	0.016	0.016
9	3.46	0.003	0.006	0.004	0.004	0.006	0.005
10	4.69	0.002	0.001	0.000	0.000	0.000	0.001
11	6.20	0.000	0.000	0.000	0.000	0.000	0.000
12	8.37	0.000	0.000	0.000	0.000	0.000	0.000

OPC Bin, i	\bar{d}_i µm	Penetration data reduction			Uncertainty limits		Efficiency %
		P	δ	e	Static	Dynamic	
1	0.35	0.535	0.018	0.023	0.05	0.037	Pass 46.5
2	0.47	0.425	0.013	0.016	0.05	0.030	Pass 57.5
3	0.62	0.337	0.010	0.013	0.05	0.024	Pass 66.3
4	0.84	0.237	0.006	0.008	0.05	0.017	Pass 76.3
5	1.14	0.144	0.009	0.011	0.05	0.010	Pass 85.6
6	1.44	0.096	0.005	0.007	0.05	0.007	Pass 90.4
7	1.88	0.049	0.005	0.007	0.05	0.003	Pass 95.1
8	2.57	0.018	0.001	0.001	0.05	0.001	Pass 98.2
9	3.46	0.005	0.001	0.001	0.05	0.001	Pass 99.5
10	4.69	0.001	0.001	0.001	0.05	0.000	Pass 99.9
11	6.20	0.000	0.000	0.000	0.05	0.000	Pass 100.0
12	8.37	0.000	0.000	0.000	0.05	0.000	Pass 100.0

\bar{d}_i	Geometric mean diameter of a size range i, µm	$U_{e,tot}$	Total upstream particle counts
$U_{B,e,b}$	Upstream begining background count for penetration	$D_{e,tot}$	Total downstream particle counts
$U_{B,e,f}$	Upstream final background count	P_o	Observed penetration, -
$U_{B,e}$	Upstream background count average for penetration	P	Penetration, -
$D_{B,e,b}$	Downstream begining background count for penetration	δ_o	Standard deviation of the observed penetration
$D_{B,e,f}$	Downstream final background count	δ	Standard deviation of the penetration
$D_{B,e}$	Downstream background count average for penetration	e	Uncertainty at 95 % confidence interval for penetration values




FINAS
Finnish Accreditation Service
T001 (EN ISO/IEC 17025)

The results are only valid for the tested sample(s).
This report may be published in its entity, parts of it only with a written permission by Eurofins

**Normalized downstream particle size distribution and measured efficiencies
EN ISO 16890-1,2,4:2016**

Air filter: CA-Q
Test no.: 204224
Test aerosols: DEHS (0.3 - 1 μm) and KCl (1 - 10 μm)
Air flow rate: 0.097 m^3/s



Particle size			Urban size distribution				Rural size distribution			Fractional efficiency			
Δd_i μm	\bar{d}_i μm	$\Delta \ln d_i$ μm	$q_{3u}(\bar{d}_i)$	$q_{3u}(\bar{d}_i)^* / \Delta \ln d_i$	$E_{D,i} q_{3u}(\bar{d}_i) / \Delta \ln d_i$	$E_{A,i} q_{3u}(\bar{d}_i) / \Delta \ln d_i$	$q_{3r}(\bar{d}_i)$	$q_{3r}(\bar{d}_i)^* / \Delta \ln d_i$	$E_{A,i} q_{3r}(\bar{d}_i) / \Delta \ln d_i$	Initial, E_i %	Conditioned $E_{D,i}$ %	Average $E_{A,i}$ %	
0.30 - 0.40	0.35	0.28768	0.22627	0.065095	0.031898	0.030267	0.031082	0.094121	0.027077	0.012929	49	46	48
0.40 - 0.55	0.47	0.31845	0.19891	0.063343	0.037638	0.036415	0.037027	0.083946	0.026733	0.015627	59	57	58
0.55 - 0.70	0.62	0.24116	0.15837	0.038193	0.026040	0.025319	0.025679	0.074324	0.017924	0.012051	68	66	67
0.70 - 1.00	0.84	0.35667	0.11522	0.041097	0.031732	0.031349	0.031540	0.070137	0.025016	0.019199	77	76	77
1.00 - 1.30	1.14	0.26236	0.08503	0.022309	0.019602	0.019098	0.019350	0.076281	0.020013	0.017359	88	86	87
1.30 - 1.60	1.44	0.20764	0.07618	0.015817	0.014502	0.014291	0.014397	0.088326	0.018340	0.016693	92	90	91
1.60 - 2.20	1.88	0.31845	0.08022	0.025546	0.024299	0.024299	0.024299	0.108042	0.034406	0.032727	95	95	95
2.20 - 3.00	2.57	0.31015	0.09984	0.030966	0.030378	0.030409	0.030394	0.137262	0.042573	0.041786	98	98	98
3.00 - 4.00	3.46	0.28768	0.12688	0.036500	0.036300	0.036321	0.036310	0.167084	0.048067	0.047817	99	100	99
4.00 - 5.50	4.69	0.31845	0.15556	0.049537	0.049473	0.049488	0.049481	0.195424	0.062233	0.061622	100	100	100
5.50 - 7.00	6.20	0.24116	0.17757	0.042823	0.042778	0.042823	0.042800	0.216707	0.052261	0.052234	100	100	100
7.00 - 10.0	8.37	0.35667	0.19157	0.068329	0.068262	0.068329	0.068296	0.231428	0.082545	0.082505	100	100	100

Symbols and units

- Δd_i Particle size range, μm
- \bar{d}_i Geometric mean diameter of a size range i , μm
- $\Delta \ln d_i$ Logarithmic width of particle diameter size range i
- $q_{3u}(\bar{d})$ Discrete urban particle volume distribution, dimensionless
- $q_{3r}(\bar{d})$ Discrete rural particle volume distribution, dimensionless
- E_i Initial fractional efficiency of particle size range i of the untreated and unloaded filter element, %
- $E_{D,i}$ Fractional efficiency of particle size range i of the filter element after an artificial conditioning step, %
- $E_{A,i}$ Average fractional efficiency of particle size range i , %
- $e\text{PM}_{x,\text{ini}}$ Initial particulate matter efficiency value of the clean filter, %
- $e\text{PM}_{x,\text{min}}$ Minimum particulate matter efficiency value of the conditioned filter, %
- $e\text{PM}_x$ Particulate matter efficiency, %

Particulate matter efficiencies		
$e\text{PM}_{1,\text{ini}}$	$e\text{PM}_{1,\text{min}}$	$e\text{PM}_1$
61 %	59 %	60 %
$e\text{PM}_{2.5,\text{ini}}$	$e\text{PM}_{2.5,\text{min}}$	$e\text{PM}_{2.5}$
71 %	70 %	71 %
$e\text{PM}_{10,\text{ini}}$	$e\text{PM}_{10,\text{min}}$	$e\text{PM}_{10}$
91 %	90 %	90 %
		ISO $e\text{PM}_{10}$ 90 %



The results are only valid for the tested sample(s).
This report may be published in its entity, parts of it only with a written permission by Eurofins

**The interpretation of test reports
ISO 16890-1:2016**

This brief review of the test procedures, including those for addressing the testing of electrostatic charged filters, is provided for those unfamiliar with the procedures of this series of ISO standards. It is intended to assist in understanding and interpreting the results in the test report/summary (for further details of procedures, the full ISO 16890 document series shall be consulted).

Air filters may rely on the effects of passive static electric charges on the fibres to achieve high efficiencies, particularly in the initial stages of their working life. Environmental factors encountered in service may affect the action of these electric charges so that the initial efficiency may drop substantially after an initial period of service. This could be offset or countered by an increase in efficiency ("mechanical efficiency") as dust deposits build up. The reported, untreated and conditioned (discharged) efficiency shows the extent of the electrical charge effect on initial performance and indicates the potential loss of particle removal efficiency when the charge effect is completely removed and when, at the same time, there is no compensating increase of the mechanical efficiency.

These test results should not be assumed to represent the filter performance in all possible environmental conditions or to represent all possible "real-life" behaviour.

Instruments used in the test				
Instrument	Type code	Serial number	Calibration date	Used
Micromanometer	Furness C012	209103	23.7.2020	X
	Furness C012	1211165	23.7.2020	X
	MicaFlex-PD	32760-068	23.7.2020	X
Barometer	Vaisala PTB330	F4340001	23.7.2020	X
Hygrometer	Vaisala HMT333	D3940024	2.12.2019	X
Temperature meter	Agilent 34970A	MY44034623	21.7.2020	X
Balance	Precisa XB10200D-IP65	5300037	31.1.2020	X
	DFWATEX2GD-1	93411584	4.11.2019	X
Particle counter	TSI 3330	3330152501	20.5.2020	X
	TSI 3330	3330160801	20.5.2020	X
DEHS aerosol generator	ISO 16890-2:2016	-	-	X
KCl aerosol generator	TSI 8108	8108153201	-	X
Dust feeder	TOPAS SAG 440	440 13 03 406	31.10.2019	-
Orifice plate	φ 216 mm / (610 x 610) mm	-	8.9.1999	X
	φ 272 mm / (610 x 610) mm	-	25.5.1999	-
	φ 90 mm / (610 x 610) mm	-	17.3.2005	-